WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50918
Permit No.
Basin

NOTICE OF INTENT NO. 15056

1. OWNER Gerald Levis
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2650 W. Shadow Mt. St.

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 20 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 36-521-02 (Parcel No.) Shadow Mt. Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	11	6
Calichie		11	14	3
Clay		14	22	8
Calichie		22	25	3
Clay		25	35	10
Calichie		35	37	2
Clay		37	44	7
Calichie		44	46	2
Clay		46	53	7
Calichie	WB	53	57	4
Clay		57	69	12
Calichie	WB	69	72	3
Clay		72	88	16
Calichie	WB	88	93	5
Clay		93	109	16
Calichie	WB	109	112	3
Clay		112	119	7
Calichie	WB	119	121	2
Clay		121	127	6
Calichie	WB	127	129	2
Clay		129	136	7
Calichie	WB	136	140	4

Date started 3-6 19 96
Date completed 3-8 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) P.O. Box 4220
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 3-14-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627