WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50922
Permit No.
Basin 039

NOTICE OF INTENT NO. 30396

1. OWNER Jarbridge Water Users Assoc.
MAILING ADDRESS P.O. Box 260050
Jarbridge, NV 89826
ADDRESS AT WELL LOCATION Jarbridge, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 17 T 46 N/S R 58 E Elko County
PERMIT NO. (Issued by Water Resources) Parcel No. Tract of Land (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Gravel, boulders	X	3	22	19
Small gravel/clay		22	45	23
Brown rock		45	85	40
Small gravel	X	85	90	5
Red rock		90	110	20
Gravel	X	110	130	20
Rock/clay		130	173	43
Gravel	X	173	190	17
Brown yellow rock		190	215	25
Gravel/sand	X	215	260	45
Rock		260	275	15
Gravel	X	275	290	15
Clay/rock		290	335	45

Pumped bentonite from bottom of hole to 50 ft.
Pumped cement from 50 ft. to surface

Date started January 4, 19 96
Date completed January 5, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	75		1 hour

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
5-1/2 Inches		0 Feet	335 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 48 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O.Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed (By driller performing actual drilling on site or contractor)
Date 1-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627