



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15090

1. OWNER Everett Charette ADDRESS AT WELL LOCATION 1110 Piltz  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 8 T 20 S N/S R 53 E Nye County  
 PERMIT NO. 35-151-26 Parcel No. \_\_\_\_\_ Subdivision Name Cal Vegas Ranchos  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	5	5
Caliche		5	7	2
Clay		7	14	7
Caliche		14	16	2
Clay		16	28	12
Caliche		28	31	3
Clay		31	43	12
Caliche		43	48	5
Clay		48	51	3
Caliche	WB	51	54	3
Clay		54	62	8
Caliche	WB	62	65	3
Clay		65	77	12
Caliche	WB	77	81	4
Clay		81	89	8
Caliche	WB	89	94	5
Clay		94	99	5
Caliche	WB	99	101	2
Clay		101	114	13
Caliche	WB	114	116	2
Clay		116	126	10
Caliche	WB	126	128	2
Clay		128	137	9
Caliche	WB	137	140	3

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
12 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation factory saw cut  
 Size perforation 1 7/8" x 3"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address P.O. Box 4220 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 3-15-96

Date started February 22 19 96  
 Date completed February 24 19 96

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

