WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50934
Permit No.
Basin 162

NOTICE OF INTENT NO. 15059

1. OWNER Ahnyson Woodward
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4831 Cheyenne Way

2. LOCATION SE ¼ SE ¼ Sec. 20 T. 21 S N/S R. 54 E. N Y E. County
PERMIT NO. (Issued by Water Resources) 45-303-06 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6'
Caliche		6	9	3'
Clay		9	14	5'
CALICHE		14	16	2'
clay		16	23	7'
CALICHE		23	25	2'
CLAY		25	39	14'
CALICHE		39	43	4'
CLAY		43	55	12'
CALICHE		55	57	2'
CLAY		57	64	7'
Caliche		64	69	5'
Clay		69	78	9'
Caliche		78	81	3
Clay		81	92	11'
Caliche		92	94	2'
Clay		94	98	4'
LIMESTONE	W.B.	98	106	8'
Clay		106	119	13'
caliche	W.B.	119	121	2'
clay		121	134	13'
Caliche	WB	134	137	3'
CLAY		137	140	3'

DCNR/DWR Engineering MAR 26 1996 LAS VEGAS OFFICE

Date started 3-6, 19 96
Date completed 3-8, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dean
By driller performing actual drilling on site or contractor
Date 3-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627