WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50940
Permit No.
Basin 162

NOTICE OF INTENT NO. 16888

1. OWNER Lion Fugit
MAILING ADDRESS 560 McMurray
Pahrump, NV 89041

ADDRESS AT WELL LOCATION 560 McMurray
Pahrump, NV 89041

2. LOCATION SE ¼ NW ¼ Sec. 28 T 19S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 29-902-13 (Parcel No.) Belvista no.3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	8	8
Dec Calichia		8	20	12
Brown Clay		20	25	5
Calichia		25	45	20
Brown Clay	x	45	62	17
Calichia	x	62	70	8
Red Sandy Clay	x	70	76	6
Brown Clay	x	76	85	9
Calichia	x	85	98	13
Brown Clay	x	98	113	15
Calichia	x	113	140	27
Red Sandy Clay	x	140	147	7
Sandy Gravel	x	147	165	18
Dec Calichia	x	165	182	17
Brown Clay	x	182	195	13
Red Sandy Clay	x	195	200	5

Date started April 1, 19 96
Date completed April 2, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	NA	½

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
Type perforation Torch
Size perforation ¼ x 4
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 150 feet to 200 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Jenkins
Contractor
Address P.O. Box 3392
Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date 4-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627