

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15028**

1. OWNER Joe Matranga ADDRESS AT WELL LOCATION 980 W. Megan
MAILING ADDRESS _____
2. LOCATION NE 1/4 SW 1/4 Sec. 16 T. 19 S N/S R. 53 E. NVE County _____
PERMIT NO. 29-251-23 Country Place # _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	7	7'
CALICHE		7	9	2'
CLAY		9	13	4'
CALICHE		13	15	2'
CLAY		15	36	21'
CALICHE		36	38	2'
CLAY		38	49	11'
CALICHE		49	51	2'
CLAY		51	64	13'
CALICHE	WB	64	67	3'
CLAY		67	78	11'
CALICHE	WB	78	81	3'
CLAY		81	101	20'
CALICHE	WB	101	104	3'
CLAY		104	113	9'
CALICHE	WB	113	116	3'
CLAY		116	127	11'
CALICHE	WB	127	129	2'
CLAY		129	138	9'
CALICHE	WB	138	143	5'
CLAY		143	152	9'
CALICHE	WB	152	155	3'
CLAY		155	160	5'

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Feet To 160 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
Type perforation Factory Sawcut
Size perforation 1 1/2" X 3"
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 2-15, 1996
Date completed 2-17, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address P.O. Box 4220 Contractor
Pahrump NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30850
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 3-6-96