

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15035

1. OWNER Carey Trammel ADDRESS AT WELL LOCATION 4301 E. SAWAY  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec. 20 T 21 S N/S R 54 E County Nye  
 PERMIT NO. 45-311-07 Parcel No. \_\_\_\_\_ Subdivision Name Green Saddle Ranch

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Caliche		5	7	2
Clay		7	24	17
Caliche		24	27	3
Clay		27	39	12
Caliche		39	44	5
Clay		44	53	9
Caliche		53	57	4
Clay		57	67	10
Caliche	WB	67	69	2
Clay		69	78	9
Caliche	WB	78	81	3
Clay		81	84	3
Caliche	WB	84	97	13
Clay		97	106	9
Caliche	WB	106	108	2
Clay		108	112	4
Caliche	WB	112	114	2
Clay		114	118	4
Caliche	WB	118	121	3
Clay		121	134	13
Caliche	WB	134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 1 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16-94</u>	<u>1.88</u>	<u>0</u>	<u>140</u>


Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 1/8" x 3"

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet



Date started February 19 1996  
 Date completed February 21 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 67 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address P.O. Box 4220 Contractor  
Rahrump, NV 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan  
 By driller performing actual drilling on site or contractor

Date 2-27-96