WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50979
Permit No.
Basin 162

NOTICE OF INTENT NO. 16032

1. OWNER Gus Mitropanopoulos
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2191 N. Blagg

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-602-10 (Parcel No.) Gerald Martin (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Calichie		7	9	2
Clay		9	21	12
Calichie		21	24	3
Clay		24	38	14
Calichie		38	40	2
Clay		40	52	12
Calichie	WB	52	55	3
Clay		55	63	8
Calichie	WB	63	65	2
Clay		65	78	13
Calichie	WB	78	80	2
Clay		80	96	16
Calichie	WB	96	98	2
Clay		98	112	14
Calichie	WB	112	117	5
Clay		117	124	7
Calichie	WB	124	126	2
Clay		126	135	9
Calichie	WB	135	139	4
Clay		139	145	6
Calichie	WB	145	150	5

DCNR/DWR Received MAR 5 1996 LAS VEGAS OFFICE

Date started February 15, 1996
Date completed February 17, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	150

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From feet to feet
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV. 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-27-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627