

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 50994  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 16880

1. OWNER Maria Smihula ADDRESS AT WELL LOCATION Bond Street  
 MAILING ADDRESS Bond Street Pahrump, NV 89041  
 2. LOCATION NE 1/4 NW 1/4 Sec 31 T 21S N/S R. 53 E Nye County Nye  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	8	8
Dec Calichia		8	20	12
Brown Clay		20	45	25
Calichia	x	45	62	17
Brown Clay	x	62	72	10
Calichia	x	72	85	13
Red Sandy Clay	x	85	113	28
Sandy Gravel	x	113	122	9
Dec Calichia	x	122	147	25
Brown Clay	x	147	172	25
Red Sandy Clay	x	172	188	16
Dec Calichia	x	188	192	4
Brown Clay	x	192	222	30
Red Sandy Clay	x	222	235	13

8. WELL CONSTRUCTION  
 Depth Drilled 235 Feet Depth Cased 235 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 235 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	235

Perforations: Torch  
 Type perforation \_\_\_\_\_  
 Size perforation 1/4 x 4  
 From 195 feet to 215 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 185 feet to 235 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

Date started March 26, 19 96  
 Date completed March 27, 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>NA</u>	<u>1/4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry Jenkins Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1916  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4-10-96