WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50999
Permit No.
Basin 212

NOTICE OF INTENT NO. 17861

1. OWNER Buena Engineers Inc.
MAILING ADDRESS 3021 S. Valley View #104
Las Vegas NV 89102

ADDRESS AT WELL LOCATION 5380 S. Valley View & Hacienda
Las Vegas NV 89103

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2674 (Issued by Water Resources) | 162-29-203-004 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Silt Some Gravel		0	4.5'	4.5'
Caliche w/ Silt Layer		4.5'	10'	3.5'
Silty Clay & Gravel		10'	30'	20'
Fine Sand & Gravel		30'	36.5'	6.5'
Caliche		36.5'	39.5'	3'
Fine Brn. Sand & Gravel		39.5'	42'	2.5'
Cemented Sand		42'	46'	4'
Caliche		46'	51'	5'
Silty Clay & Fine Brn Sand		51'	60'	9'
Clay Brn		60'	62'	2'
F. Brn. Sand & Clay		62'	80'	18'

DCNR DWR Received FEB 9 1996 LAS VEGAS OFFICE

Date started 2-2, 1996
Date completed 2-2, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 77 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	47

Perforations:
Type perforation Slotted
Size perforation .020
From 47 feet to 77' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 43
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 77 feet to 45 feet

9. WATER LEVEL
Static water level 55' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M2017
Signed Kenneth A. Kutania (By driller performing actual drilling on site or contractor)
Date 2-6-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627