WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51000
Permit No.
Basin 212

NOTICE OF INTENT NO. 17861

1. OWNER Buena Engineers
MAILING ADDRESS 3021 S. Valley View #104 Las Vegas NV 89102
ADDRESS AT WELL LOCATION 5380 S. Valley View - Hacienda Las Vegas N.V 89103

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 21 N (S) R. 61 E. Clark County
PERMIT NO. MO-2674 (Issued by Water Resources) 162-29-203-005 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
- Fine Med Sand & Gravel		0	5'	5'
- Calinche		5'	11	6'
- Silty White Clay & Gravel		11'	16	5'
- Brn Clay		16'	23'	7'
- Brn Sand & Gravel		23'	33'	10'
- Coarse Brn Sand & Gravel		33'	40	7'
Clay & Calinche				
- Gravel & Cemented Sand & Clay		40	44	4'
- Gray Sandy Gravel		44'	52'	8'
- Gray Silty Clay		52'	57'	5'
- Sand Gravel & Clay		57'	70'	13'

DCNR/DWR Received FEB 9 1996 LAS VEGAS OFFICE

Date started 2-2, 1996
Date completed 2-2, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 70' Feet Depth Cased 69 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	70 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	49

Perforations:
Type perforation Slotted
Size perforation .020
From 49 feet to 69 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 40
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 69' feet to 44' feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 54.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2017

Signed Kenneth A. Kutcuma
By driller performing actual drilling on site or contractor
Date 2-6-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627