WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51020
Permit No.
Basin 212

NOTICE OF INTENT NO. 16564

1. OWNER Clark County Treasurer
MAILING ADDRESS 225 Bridger
Las Vegas

ADDRESS AT WELL LOCATION 1901 & 1919 Industrial Road
Las Vegas, NV.

2. LOCATION NW ¼ SE ¼ Sec. 04 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2647 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG A

Material	Water Strata	From	To	Thickness
2.5 inches AC		0.0	2.5"	2.5"
4 inches BASE		2.5"	6.5"	4"
Brown Clay (cl) Soft, moist		6.5"	8.5'	6.0'
Color change to Light Brown Stiff, dry with gravels @ 6.5ft				
Water level	8.5'			
Light Gray Clayey sand (sc) Dense, dry		8.5	12.5	4.0'
Light Gray Clay (cl) stiff saturated		12.5	15.5	3.0'

DCNR DWR Received NOV 27 1995 Las Vegas Office

Date started 10/10, 19 95
Date completed 10/13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 19.0 Feet Depth Cased 19.0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7-3/4 Inches	0.0 Feet	19.0 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.70	0.31	0.0	19.0

Perforations:
Type perforation Slotted
Size perforation 0.01
From 9.0 feet to 19.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10 1/2 ft 5 ft Bentonite 5 1/2 ft cement
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement/Bentonite ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 1/2 feet to 19.0 feet

9. WATER LEVEL
Static water level 8.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pezonella Associates Contractor
Address 520 Edison Way Contractor
Reno Nv 89502
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
Signed Dale Lahner
By driller performing actual drilling on site or contractor
Date 11-21-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627