


OFFICE USE ONLY
 Log No. 51023
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16803

1. OWNER Blake Anderson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 9442 Belcastro _____
LV NV _____
 2. LOCATION S W 1/4 SE 1/4 Sec. 22 T. 23 N/S R. 60 E County _____
 PERMIT NO. 17622701018 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand / Gravels</u>		<u>0</u>	<u>125</u>	
<u>Red Sandstone</u>		<u>125</u>	<u>140</u>	
<u>Sand Gravels</u>		<u>140</u>	<u>155</u>	
<u>Lime Stone</u>		<u>155</u>	<u>225</u>	
<u>Brown Hardrock</u>		<u>225</u>	<u>290</u>	
<u>Red Sandstone</u>		<u>290</u>	<u>305</u>	
<u>Yellow Sandstone</u>		<u>305</u>	<u>320</u>	
<u>Red Sandstone</u>	<u>2</u>	<u>320</u>	<u>410</u>	
<u>Lime Stone</u>	<u>2</u>	<u>410</u>	<u>560</u>	
<u>Lime Stone</u>	<u>40</u>	<u>560</u>	<u>560</u>	

8. WELL CONSTRUCTION
 Depth Drilled 560 Feet Depth Cased 555 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 560 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>15</u>	<u>188</u>	<u>0</u>	<u>555</u>

Perforations:
 Type perforation Touch
 Size perforation 1 1/2 inch
 From 490 feet to 555 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Cement Grout
 Depth of Seal 0-50 Neat Cement
 Placement Method: Pumped Poured Cement Grout
 Gravel Packed: Yes No
 From 50 feet to 555 feet

9. WATER LEVEL
 Static water level 410 feet below land surface
 Artesian flow no G.P.M. _____ P.S.I. _____
 Water temperature 60.6 °F Quality Good

Date started 10-30, 1995
 Date completed 12-27, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Redding Drilling Contractor
 Address 8170 S HAVEN Contractor
Las Vegas, NV 89123
 Nevada contractor's license number issued by the State Contractor's Board 38155
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798
 Signed Thomas Redding
 By driller performing actual drilling on site or contractor
 Date 12-13-95

