

WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 51026  
 Permit No. \_\_\_\_\_  
 Basin 16a  
  
 16868

*Location done should be switched. - Bobby D 5/25/10*

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

1. OWNER Red Hawk Lumber ADDRESS AT WELL LOCATION Mesquite Rd/Pahrump  
 MAILING ADDRESS Mesquite Rd. Pahrump, NV 89041

2. LOCATION SE 1/4 SW 1/4 Sec. 34 T. 19S N/S R. 53 E Nye County  
 PERMIT NO. 56800 27-401-04 Nye County  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	20	20
Dec Calichia		20	22	2
Grey Clay		22	41	19
Calichia	x	41	62	21
Brown Clay	x	62	71	9
Calichia	x	71	102	31
Brown Clay	x	102	119	17
Grey Clay	x	119	124	5
Calichia	x	124	132	8
Brown Clay	x	132	145	13
Grey Clay	x	145	169	24
Calichia	x	169	175	6
Brown Clay	x	175	180	5

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 6

From 100 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 130 feet to 180 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature Cold °F Quality Good

Date started December 20 19 95  
 Date completed December 22 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>	<u>Na</u>	<u>5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Jenkins Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 1-10-96

