WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51031
Permit No.
Basin 212

NOTICE OF INTENT NO. 16027

1. OWNER Broadbent & Assoc.
MAILING ADDRESS 833 Nevada Hwy Suite 4
Boulder City NV 89005

ADDRESS AT WELL LOCATION Avis Rent-A-Car
5164 Rent-A-Car Road
Las Vegas NV

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO 2619 A (Issued by Water Resources) 16227201005 (Parcel No.) MW-1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Top		0	3"	3"
Brn Fine-Med Sand Gravel		3"	3'	2'9"
F-Med Reddish Brn. Sand w/ Traces. OF Silt-Clay		3'	8'	5'
Caliche		8'	17.5'	9.5'
Fine-Med Silty Gray-Brn Sand + Clay Layers.		17.5'	26'	8'5"

LAS VEGAS OFFICE
JAN 19 1996
Received
DCNR/DWR

Date started Jan. 16, 1996
Date completed Jan. 16, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches		0 Feet	26' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0'	22.5'

Perforations:
Type perforation Slot
Size perforation .020
From 22.5' feet to 25' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 18'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 25' feet to 22' feet

9. WATER LEVEL
Static water level 19' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants Western (Contractor)
Address 4343 South Polaris Ave. (Contractor)
Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1944
Signed Thomas M. Beall (By driller performing actual drilling on site or contractor)
Date 1-17-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627