WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51644
Permit No.
Basin 162

NOTICE OF INTENT NO. 16942

1. OWNER Bill Davis
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3090 Gay St.

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 19s N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 27-381-61 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	18	13
Calichie		18	21	3
Clay		21	38	17
Calichie		38	41	3
Clay		41	55	14
Calichie	WB	55	58	3
Clay		58	71	13
Calichie	WB	71	74	3
Clay		74	89	15
Calichie	WB	89	93	4
Clay		93	108	15
Calichie	WB	108	110	2
Clay		110	118	8
Calichie	WB	118	121	3
Clay		121	132	11
Calichie	WB	132	134	2
Clay		134	139	5
Calichie	WB	139	140	1

DCNR/DWR Received FEB 26 1996 LAS VEGAS OFFICE

Date started January 22, 19 96
Date completed January 24, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem (By driller performing actual drilling on site or contractor)
Date 1-26-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627