WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

1st Book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51045
Permit No.
Basin 162

NOTICE OF INTENT NO. 16938

1. OWNER Jack Hennigan
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3751 Underbrush

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 20S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 41-142-01 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	13	13
Calichie		13	16	3
Clay		16	23	7
Calichie		23	25	2
Clay		25	39	14
Calichie		39	44	5
Clay		44	52	8
Calichie	WB	52	55	3
Clay		55	63	8
Calichie	WB	63	66	3
Clay		66	72	6
Calichie	WB	72	75	3
Clay		75	83	8
Calichie	WB	83	86	3
Clay		86	91	5
Calichie	WB	91	97	6
Clay		97	118	21
Calichie	WB	118	122	4
Clay		122	135	13
Calichie	WB	135	140	5

DCNR/DWR Received FEB 26 1996 LAS VEGAS OFFICE

Date started January 1-23, 1996
Date completed January 1-26, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8" x 31"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 4220 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun
By driller performing actual drilling on site or contractor
Date 1-26-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627