WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51049
Permit No.
Basin

NOTICE OF INTENT NO. 16947

1. OWNER Tom Gielow
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1900 Sutton St.

2. LOCATION SW ¼ SW ¼ Sec. 24 T. 20 S N/S R. 52 E. NYE County
PERMIT NO. (Issued by Water Resources) 28-482-12 (Parcel No.) Wagon Wheel (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Caliche		2	5	3'
Clay		5	11	6'
Caliche		11	13	2'
Clay		13	29	16'
Caliche		29	32	3'
Clay		32	54	22'
Caliche	W.B	54	57	3'
Clay		57	65	8'
Caliche	W.B	65	68	3'
Clay		68	85	17'
Caliche	W.B	85	89	4'
Clay		89	104	15'
Caliche	W.B	104	106	2'
Clay		106	117	11'
Caliche	W.B.	117	122	5'
Clay		122	128	6'
Caliche	W.B.	128	130	2'
Clay		130	136	6'
Caliche	W.B.	136	140	4'

DCNR-DWR Received FEB 26 1996 LAS VEGAS OFF.

Date started 1-25, 1996
Date completed 1-28, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0 Feet	140' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) P.O. box 4220
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-15-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627