

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **13191**

1. OWNER Ken Lackey ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T. 19-S N/S R. 53 E Nye County
 PERMIT NO. APN 29-882-27 27 Unit 3 Block 4 Bell Vista Sub.
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Soft Brown Clay		4	44	40
Hard Pan		44	50	6
Soft Brown Clay		50	88	38
LG Gravel / Clay	x	88	115	27
Cemented Gravel		115	121	6
Brown Clay		121	136	15
Gravel / Clay	x	136	166	30
Hard Cemented Area		166	174	8
Brown Clay	x	174	200	26

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From To
1.2 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	200

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4 in width 8 in long
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address HCR 77 BOX 36525 Pahrump, NV Contractor
 Nevada contractor's license number 7484 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date February 1, 1996

Date started January 29, 1996.
 Date completed January 31, 1996.

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>4</u>	<u>1/4</u>

