

OFFICE USE ONLY  
 Log No. 51086  
 Permit No. \_\_\_\_\_  
 Basin 16a

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16629

1. OWNER Bill Chamberlain ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec. 31 T. 21-5 N/S R. 54 E NYE County \_\_\_\_\_  
 PERMIT NO. APN 45-451-01 46 Cal-Vista Sub Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Gravel		0	12	12
Hard Pan		12	24	12
Red-Brown Clay		24	108	84
Hard Sandstone		108	116	8
Soft Brown Clay	x	116	172	56
Hard Sandstone		172	176	4
Soft Brown Clay		176	208	32
Gypsum Formation	x	208	218	10
Brown Clay		218	240	22

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	240

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in width 8 in long  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 240 feet



9. WATER LEVEL  
 Static water level 1.16 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor  
 Address HCR 77 BOX 36525 Contractor

Nevada contractor's license number 7484 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg By driller performing actual drilling on site or contractor  
 Date April 1 1996

Date started March 25, 1996  
 Date completed March 29, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4