


OFFICE USE ONLY
 Log No. 51130
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17602

1. OWNER Boulder Sahara, Inc ADDRESS AT WELL LOCATION 3501 E Sahara
 MAILING ADDRESS 7932 Alay Dr. Ave Las Vegas NV 89121
Sun Valley, CA 91352

2. LOCATION SW 1/4 SW 1/4 Sec. 6 T 21 N 62 E Clark County
 PERMIT NO. MD 2693 161-06-402-002 -NA-
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW 1-4</u>				
<u>Brown Sandy gravel with silt</u>		<u>0</u>	<u>2.5</u>	<u>2.5</u>
<u>Brown Clayey Sandy soil</u>		<u>2.5</u>	<u>9.5</u>	<u>7.0</u>
<u>Gray Silty Sand coarse some gravels</u>		<u>9.5</u>	<u>20</u>	<u>10.5</u>
<u>Dark grey fat clay</u>		<u>20</u>	<u>22</u>	<u>2</u>

8. WELL CONSTRUCTION
 Depth Drilled 22 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet 22 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>.308</u>	<u>0</u>	<u>7</u>

Perforations:
 Type perforation slotted screen
 Size perforation 1020
 From 7 feet to 22 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 5' feet to 22' feet



Date started March 14 1996
 Date completed March 15 1996

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2.7</u>	<u>total</u>	<u>45 min</u>

9. WATER LEVEL
 Static water level 10.4 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature cool °F Quality Contaminated

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Les Jones Contractor
 Address 7560 W. Sahara St. 101 Contractor
Las Vegas, Nevada 89117
 Nevada contractor's license number N/A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11-1980
 Signed Les Jones
 By driller performing actual drilling on site or contractor
 Date 4-4-96