WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

RECEIVED DWR OCT 30 1995 LAS VEGAS OFFICE

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51149
Permit No.
Basin 212

NOTICE OF INTENT NO. 14077

1. OWNER Broadbent & Assoc
MAILING ADDRESS 873 Nevada Hwy
Boulder City NV 89005

ADDRESS AT WELL LOCATION
Sun Express Eastern & Owens

2. LOCATION NW ¼ NW ¼ Sec. 25 T 21 N/S R 61 E/W Clark County

PERMIT NO: mo-2434c
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 15 | |
| Clay w/caliche | | 15 | 17 | |
| Clay w/ some Fines | | 17 | 27.5 | |

Date started 6-20, 1995
Date completed 6-20, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 27.5 Feet Depth Cased 27.5 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 27.5 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.5 | PVC | sch 80 | 0 | 25 |
| | | | | |

Perforations:
Type perforation slotted screen
Size perforation .020
From 25 feet to 27.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 23
Placement Method: ☐ Pumped ☑ Poured

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 24 feet to 27.5 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weber Environmental Inc.
Contractor
Address 4301 S. Valley View #21
Contractor
LV NV 89103

Nevada contractor's license number issued by the State Contractor's Board 0039526

Nevada driller's license number issued by the Division of Water Resources, the on-site driller m1847

Signed
By driller performing actual drilling on site or contractor

Date 10-12-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627