

OFFICE USE ONLY  
 Log No. 51156  
 Permit No. 173B  
 Basin. T

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28881

1. OWNER Phillips Petroleum Co. ADDRESS AT WELL LOCATION Appx 60 miles South  
 MAILING ADDRESS Box 1967 West of Ely - Railroad Valley  
 Houston, TX

2. LOCATION SE 1/4 NW 1/4 Sec. 21 T. 09 N/S R. 56 E. Nye County  
 PERMIT NO. Waiver OG-193 Sidewinder NO. 1-3  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	20	20
Clay Sand & Gravel		20	25	5
Sand & Gravel		25	50	25
Clay Sand & Gravel		50	55	5
Water Bearing Sand & Gravel	x	55	110	55
Clay Sand & Gravel		110	145	35
Water Bearing Sand & Gravel	x	145	150	5
Clay Sand & Gravel		150	155	5
Water Bearing Sand & Gravel	x	155	180	25

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 180 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	180

Perforations: Factory  
 Type perforation 1/8" x 2 1/2" 6 rows  
 Size perforation 1/8" x 2 1/2" 6 rows  
 From 80 feet to 180 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature Cold °F Quality Good

Date started November 28, 19 95  
 Date completed November 30, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	200	100	1

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
 Ely, NV 89301  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
 Signed *Jarvis Christiansen*  
 By driller performing actual drilling on site or contractor  
 Date December 1, 1995

RECEIVED  
 NOV 29 7 AM 1995  
 DIVISION OF WATER RESOURCES