200-16

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51158
Permit No.
Basin 137B

NOTICE OF INTENT NO. 31336

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS P.O. Box 480
Round Mountain, Nv 89045

ADDRESS AT WELL LOCATION Minesite

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 10 N/S R. 44 E. Nye County
PERMIT NO. 61567 (Issued by Water Resources) Parcel No. RMGC open pit minesite (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Poorly Welded Tuff | | 0 | 165 | |
| Volcanics | ✓ | 165 | 280 | |
| Quartzite | | 280 | 285 | |
| interbedded Phyllite/Quartzite | | 285 | 370 | |
| Phyllite | | 370 | 410 | |

Date started 11-18, 1995
Date completed 11-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | N/A | |

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 410 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 20 Inches | 0 Feet | 50 Feet | |
| 15 Inches | 50 Feet | 410 Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 16" | 52.36 | .250 | 0 | 50 |
| 10¾ | 28.04 | .250 | +3 | 410 |

Perforations:
Type perforation Roscoe-Moss Shudder Screen
Size perforation ⅛ x 3
From 190 feet to 210 feet
From 250 feet to 270 feet
From 310 feet to 350 feet
From 390 feet to 410 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow +100 G.P.M. P.S.I.
Water temperature Unk °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co. (Contractor)
Address 2210 Stowe Dr. (Contractor)
Reno, Nv 89511
Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Lee Woytek (By driller performing actual drilling on site or contractor)
Date 11-22-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627