WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51186
Permit No.
Basin 103

NOTICE OF INTENT NO. 28024

1. OWNER Alex Creighton
MAILING ADDRESS 11345 Silver Ln. Stagecoach NV.
ADDRESS AT WELL LOCATION 11345 Silver Ln. Stagecoach NV.

2. LOCATION SW ¼ NE ¼ Sec. 17 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. 50249 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands		0	8	8
Hard Pack Clay				
Course Sands		8	65	
DG Gravels				
Obsidian Course		65	210	
Sands w/small Clay	xxx	165	210	
Balls				
Brown Clay Seem		210	220	
Course Gravels	xxx	220	273	
and Clay Seems				
Small Course Sands	xx	273	325	
Solid Brown Clay		325	365	
w/Broken Seams				
of Gravels				

Date started 10-14, 1995
Date completed 10-20, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200+	65	6 HRS

8. WELL CONSTRUCTION
Depth Drilled 365 Feet Depth Cased 365 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	365 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.65	.188	0	365

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 160 feet to 180 feet
From 220 feet to 260 feet
From 325 feet to 365 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 105 feet to 365 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. 200+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hoek (By driller performing actual drilling on site or contractor)
Date 10-23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627