WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51187
Permit No.
Basin 73 179

NOTICE OF INTENT NO. 27979

1. OWNER William J. Henroid
MAILING ADDRESS Pleasant Valley Route Box 612 Trout Creek Ut 84083
ADDRESS AT WELL LOCATION Lot 114 Lackawana Rd. & pole line rd.

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 5-601-20 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
Hard pan		1	3	
gravel clay conglomerate		3	55	
Clay conglomerate		55	60	
clay gravel con.		60	65	
gravel con.		65	115	
Sandy Clay		115	118	
gravel	water	118	120	
gravel con.		120	134	
clay		134	137	
gravel	water	137	138	
Sandy cl		138	142	
gravel	water	142	143	
Sandy Clay		143	150	
gravel	water	150	152	
Sandy Clay		152	159	
gravel	water	159	160	

RECEIVED 95 DEC -5 AM 11:55 STATE ENGINEER'S OFFICE

Date started Oct 24, 1995
Date completed Nov 16, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	1hr.

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
8 Inches		60 Feet	160 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	160

Perforations:
Type perforation mill
Size perforation 5/8 x 2.5 x 6 row
From feet to feet
From 119 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 160 feet

9. WATER LEVEL
Static water level 116 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orson Maynard (By driller performing actual drilling on site or contractor)
Date Dec 1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627