

OFFICE USE ONLY  
 Log No. 5189  
 Permit No. \_\_\_\_\_  
 Basin 102  
 NOTICE OF INTENT NO. 31983

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ray Sinclair ADDRESS AT WELL LOCATION 3780 Lemon St. Silver Springs, NV  
 MAILING ADDRESS 3780 Lemon Street Silver Springs, NV 89429  
 2. LOCATION NW 1/4 NW 1/4 Sec. 29 T. 18 R. 25 Lyon County  
 PERMIT NO. 18-416-14 Issued By Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Clay		3	55	52
Sand		55	58	3
Clay		58	80	22
Gray sand		80	85	5
Gray Clay		85	90	5
Tule Clay		90	100	10
Tule sand		100	140	40
Brown Clay		140	145	5
Brown sand & Gravel	/	145	160	15

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 52 Feet  
6 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation 4 1/2 inch torch cut  
 Size perforation 1 1/8 x 3  
 From 150 feet to 158 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 35' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cold °F Quality good

Date started 28 Sept, 1995  
 Date completed Oct 9, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>	<u>6'</u>	<u>4</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon Cannon Jr. Contractor  
 Address 4555 Hwy 50 W Silver Springs, NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23317  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455  
 Signed Vernon Cannon Jr.  
 By driller performing actual drilling on site or contractor  
 Date 11 Oct 95