

OFFICE USE ONLY
 Log No. 51175
 Permit No. _____
 Basin. 6-81
 NOTICE OF INTENT NO. 18263

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER ASAMERA MINERALS, INC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6121 Lakeside Dr Suite 130 Tracy Exit - I-80
Reno, Nv 89511-8502 off Gooseberry Mine Rd
 2. LOCATION NW 1/4 SE 1/4 Sec. 19 T. 19 N/S R. 23 E Storey County _____
 PERMIT NO. W353 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan		0	4	4
Volcanic multi colored rock		9	93	84
Brown clay		93	96	3
Volcanic multi colored rock with traces of brown and tan clay		96	261	165
More clay than rock		261	420	159
Clay very heavy in volcanic rock		420	601	181
Greenish rock with some brown clay		601	699	99
T.D. 699 feet				
This bore hole was cased graveled & sealed. There is no water from either set of perforations. No static water level.				

8. WELL CONSTRUCTION
 Depth Drilled 699 Feet Depth Cased 699 Feet
 HOLE DIAMETER (BIT SIZE)

10	Inches	From 0	To 55	Feet
8	Inches	55	699	Feet

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	699

 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 399 feet to 439 feet
 From 639 feet to 659 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 52 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 280 feet

Date started 10/22/91, 19_____
 Date completed 10/30/91, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	0		4 hours

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 11/1/91