

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No 31857

1. OWNER Lowell Phenix & Kathy Maddox ADDRESS AT WELL LOCATION 1275 Goldstone Rd. Lot 38
 MAILING ADDRESS P.O. Box 3243
Reno, Nevada 89505

2. LOCATION N 1/4 NE 1/4 Sec. 25 T. 22 N/S R. 18 E Washoe County
 PERMIT NO. 079-352-14 Parcel No. Red Rock Estates 438 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan Yellow D.G. Sands & Tan Clay		0	3	
Green Clay		3	8	
Tan Clay		8	38	
Green Clay with Yellow White Green D.G. Sands		38	72	
Green Clay with Green Vol Sands		72	770	
770 T.D.				

8. WELL CONSTRUCTION
 Depth Drilled 770 Feet Depth Cased 770 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10-5/8	0	62		
8-1/2	62	540		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	188	+1-1/2	540
5"	6.56	188	530	770

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3"
 From 300 feet to 280 feet
 From 520 feet to 500 feet
 From 750 feet to 730 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 65
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 540 feet to 65 feet

9. WATER LEVEL
 Static water level 320 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started November 8, 19 95
 Date completed November 15, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>	<u> </u>	<u>4-1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks, Nevada 89431
 Nevada contractor's license number 0035387-A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Larry Welch
 By driller performing actual drilling on site or contractor
 Date November 20, 1995