WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 51199
Permit No.
Basin 99

NOTICE OF INTENT NO. 31494

1. OWNER Ellis Twichell
MAILING ADDRESS 216 Lemon DR 394
Reno NV 89506-8701

ADDRESS AT WELL LOCATION 15130 Rancho DR.

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. 5528 (Issued by Water Resources) 07805107 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	7	7
D.G. Brown		7	33	26
white Granit		33	41	8
Pink Granit		41	47	6
Black + white Granit		47	112	65
Brown D G		112	115	3
~~Black+white Granit~~		~~115~~	~~305~~	~~195~~
Black+white Granit	8	294	304	8
Black+white Granit		115	305	195

RECEIVED 95 NOV 31 AM 11:20 STATE ENGINEERS OFFICE

Date started 11-13, 19 95
Date completed 11-20, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	15	68	1 HR

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	+1 Feet	305 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	16	188	+1	305

Perforations:
Type perforation Factory Slot
Size perforation 6 x 1½
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 305 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Unknown °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JM Drilling (Contractor)
Address 1859 Hymer Ave (Contractor)
Sparks NV 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1940
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627