

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 51218
Permit No. _____
Basin. 001

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29494

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION NE 1/4 SE 1/4 Sec 19 T. 36 N. R. 50 E. EUREKA County
PERMIT NO. M/O-441 Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CARLIN: CLAYS & SAND		0	80	80
GRAVELS & CARLIN FORMATION	40 GPM	80	390	310
CARLIN	75 GPM	390	520	130
GRAY LIMESTONE	100 GPM	520	600	80
BLACK MUDSTONE	150 GPM	600		
FRACTURES WITH CLAY			1220	620

8. WELL CONSTRUCTION
Depth Drilled 1,220 Feet Depth Cased 1,200 Feet
HOLE DIAMETER (BIT SIZE)
From To
12-1/4 Inches 0 Feet 37 Feet
6-1/4 Inches 37 Feet 1,220 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22.36	.250	0	37
1-1/4	3.0	.191	0	350
1-1/4	3.0	.191	0	1,140

Perforations: Type perforation DRILLED HOLES
Size perforation .125
From 350 feet to 410 feet
From 1140 feet to 1200 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 57
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 310 / 1,120 feet to 430 / 1,220 feet

9. WATER LEVEL
Static water level 588 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature _____ °F Quality _____

Date started DECEMBER 12, 1995
Date completed DECEMBER 18, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100</u>	<u></u>	<u>4 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed MARK WAITE *Mark Waite*
By driller performing actual drilling on site or contractor
Date 1-12-96