



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19957

1. OWNER BLAIR HOPE ADDRESS AT WELL LOCATION LOT 6 MASON ST Block C  
 MAILING ADDRESS HCR 66-52-312  
Pahrump NEV  
 2. LOCATION NE 1/4 NW 1/4 Sec 25 T. 19S N/S R. 52 E Nye County  
 PERMIT NO. E 1/2 Issued by Water Resources Parcel No. UNIT 6 Lot 6 Subdivision Name BELL VISTA Sub

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
BRN Clay		1	6	5
GREY Clay		6	44	38
HARD BRN Clay		44	57	13
GREY Clay	WB	57	68	11
HARD GREY Clay		68	81	13
GREY Clay	WB	81	118	37
HARD BRN Clay		118	126	8
GREEN Clay	WB	126	140	14

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17</u>	<u>188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4 x 6  
 From 90 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started April 2 1996  
 Date completed April 11 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>0</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RON MAILLON Drilling Contractor  
 Address BOX 265 PAHRUMP NEV 89041 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0035704  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625  
 Signed Ron Maillon  
 By driller performing actual drilling on site or contractor  
 Date April 12 ~~1996~~ 1996