WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51256
Permit No.
Basin 162

NOTICE OF INTENT NO. 16630

1. OWNER George & Elenore Blohm
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 20-S N/S R. 53 E Nye County
PERMIT NO. APN 35-352-01 (Issued by Water Resources) | 1 Block 9 (Parcel No.) | Bolling Green Acres (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	6	6
Broken Caliche & Clay		6	14	8
Hard Caliche		14	21	7
Brown Clay		21	38	17
Hard Caliche		38	45	7
Brown Clay		45	50	5
Hard Limestone		50	72	22
Brown Clay	x	72	102	30
Caliche		102	111	9
Brown Clay	x	111	132	21
Caliche		132	136	4
Brown Clay	x	136	152	16
Soft Caliche		152	176	24
Brown Clay	x	176	196	30
Caliche		196	200	4

DCNR/DWR Received APR 25 1996 LAS VEGAS OFFICE

Date started April 9, 1996
Date completed April 15, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	½

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ½ in width 8 in long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 Pahrump, NV. 89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Chas Nyberg (By driller performing actual drilling on site or contractor)
Date April 23, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627