WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51315
Permit No.
Basin 592

NOTICE OF INTENT NO. 31950

1. OWNER VINCE CANIZARRO
MAILING ADDRESS 11305 DEADWOOD
RENO, NV 89506

ADDRESS AT WELL LOCATION
10800 Silver Knolls Blvd

2. LOCATION NW 1/4 NW 1/4 Sec. 25 T 21N N/S R 18E E WASHOE County
PERMIT NO. (Issued by Water Resources) | Parcel No. 086-181-16 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2-3 GPM @ 170' 20-25 GPM @ 225-240'				
Top soil		0	4	4
Yellow clay w/ sand		4	10	6
See next line		10	85	75
Yellow, white & black coarse sand				
Green clay		85	89	4
See next line		89	148	59
Coarse sand w/ clay stringers				
Brown clay		148	165	17
Multi colored coarse sand	X	165	187	22
Brown clay		187	191	4
Multi colored coarse sand	XX	191	241	50

Date started 5/17/96, 19__
Date completed 5/18/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION

Depth Drilled 241 Feet Depth Cased 241 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	241	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.93	.188	0	241

Perforations:
Type perforation FACTORY
Size perforation .090 X 3" X 5 AROUND
From 221 feet to 241 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 90'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality NOT TESTED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 5-21-96