WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51366
Permit No.
Basin 212

NOTICE OF INTENT NO. 16307

1. OWNER UNIVERSITY CAR WASH C/O BROADBENT + ASSOC.
MAILING ADDRESS 833 NEVADA HWY STE 4 BOULDER CITY NV 89005
ADDRESS AT WELL LOCATION UNIVERSITY CAR WASH 4590 S. MARYLAND PKWY, LAS VEGAS NV

2. LOCATION NW ¼ SW ¼ Sec. 23 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2564 Issued by Water Resources
162-23-310-001 Parcel No.
Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE MW-3: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2	2
SILTY SAND		2	5	3
CALICHE		5	11	6
SILTY CLAY		11	16	5
CALICHE		16	18	2
SILTY CLAY		18	30	12

Date started JAN 25 1996
Date completed JAN 25 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	30

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-8' / 8-13' BENTONITE
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 13 feet to 30 feet

9. WATER LEVEL
Static water level 19.97 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DONALD WILSON Contractor
Address 731 PILOT RD STE H Contractor
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed By driller performing actual drilling on site or contractor
Date 2-22-96

DCNR/DWR Received MAR 7 1996 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627