WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 51418
Permit No.
Basin 107

NOTICE OF INTENT NO. 27142

1. OWNER Jim Rauber
MAILING ADDRESS 555 UPPER COLONY
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION 12 JUANITA LANE
WELLINGTON, NV 89444

2. LOCATION SW ¼ NW ¼ Sec. 12 T. 10 N/S R. 23 E/W LYON County
PERMIT NO. Issued by Water Resources | 10-711-18 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | | 0 | 15 | |
| BRN CLAY | | 15 | 35 | |
| BRN CLAY W/GRVL | | 35 | 85 | |
| BRN SANDY CLAY | | 85 | 98 | |
| SM GRVLS W/B | | 98 | 140 | |

Date started 1 22, 1996
Date completed 1 27, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | UK | 3½ |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 12¼ | 0 | 140 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | | 188 | 0 | 140 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY
Size perforation 3/32
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM 80 Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Rauber
Contractor
Address 555 UPPER COLONY
Contractor
WELLINGTON, NV 89444
Nevada contractor's license number issued by the State Contractor's Board 25120
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1949
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2/3/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627