WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 31421
Permit No.
Basin 103

NOTICE OF INTENT NO. 24735

1. OWNER MOLINE BUILDERS
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 223 FOOTHILL MEADOWS GENOA, NV

2. LOCATION SW ¼ NW ¼ Sec 10 T 13 N/S R 19 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 17-084-24 (Parcel No.) GENOA (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
DG w/Sandy clay		4	14	10
silt		14	40	26
sandy clay		40	46	6
DG w/Sandy clay		46	85	39
Sandy Clay		85	88	3
DG w/Short clay Strks.	✓	88	160	
Sandy clay		160	163	3
DG Same Sandy Clay	✓✓	163	179	16
Sandy clay		179	190	11

Date started 1-19, 1996
Date completed 1-24, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	15+		4

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	190 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.185	+2	190

Perforations:
Type perforation Factory Slotted / T.C.
Size perforation 3 x 1/8
From Factory 150 feet to 170 feet
From T.C. 170 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1-24-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627