

OFFICE USE ONLY
 Log No. 51428
 Permit No. 104
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32728
 ADDRESS AT WELL LOCATION 210 N. CARSON ST.
ALSO NEXT TO (30. OF SALVATION ARMY) CARSON CITY NV.

1. OWNER FIRST Interstate BANK
 MAILING ADDRESS 208 N. CARSON ST. CARSON CITY NV

2. LOCATION SW 1/4 SE 1/4 Sec 17 T 15 N 20 R 20 CARSON County
 PERMIT NO. MO 866 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Concrete		0	2"	
Base		2"	2'	
Brown silty sand		2'	5'	
Brown + Gray silty SAND w/ small gravel		5'	10'	
Grey clayey silt w/ gravels/ small		10'	15'	
grey SAND w/ small gravels		15'	20'	
grey SANDY silty gravel-w/ clay		20'	25'	

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)
 From 10" To 0
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>PK</u>	<u>SC40</u>	<u>0</u>	<u>10</u>

Perforations:
 Type perforation SLOT
 Size perforation .020

From 10 feet to 25 feet
 From 10 feet to 25 feet
 From 10 feet to 25 feet
 From 10 feet to 25 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 8 feet to 25 feet

Dated one Boring well.
 previous to this well constructed
 Grouted for G.W.M.W.
 this hole

MW-6

Date started 2-2, 1996
 Date completed 2-10, 1996

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 17+ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA Drilling Inc Contractor
 Address 75 Lewers creek RD Contractor
CARSON CITY NV 89704

Nevada contractor's license number 13697A
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902

Signed John A. Reich
 Driller performing actual drilling on site or contractor

Date 2-12-96