

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INVENT NO. 31940

1. OWNER ST. JAMES VILLAGE
 MAILING ADDRESS 11766 WILSHIRE BLVD
SUITE 780, LOS ANGELES, CA. 90025
 ADDRESS AT WELL LOCATION NATIA COURT AND JOY LAKE ROAD

2. LOCATION SW 1/4 SE 1/4 Sec 10 T 17 N/S R 19 E WASHOE County
 PERMIT NO. 59330
 Issued by Water Resources Parcel No. Subdivision Name THE WOODS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	71	71
SOFT SANDY CLAY		71	78	7
FRACTURED ROCK		78	88	10
GRAVEL SAND TRACE CLAY		88	135	47
HARD ROCK		135	162	27
HARD BLACK ROCK		162	222	60
FRACTURED ROCK		222	230	8
BLACK ROCK TRACE CLAY		230	236	6
FRACTURED BLACK ROCK		236	240	4
BLACK ROCK FRACTURED CLAY		240	260	20
LOST CIRCULATION		260	265	5
HARD ROCK W/ CLAY		260	299	39
RED CLAY		299	300	1
BLACK ROCK		300	338	38
BLACK ROCK W/ CLAY		338	360	22
BLACK ROCK LG. FRACTURES		360	366	6
HARD BLACK ROCK		366	374	8
FRACTURED BLACK ROCK		374	384	10
RED CLAY & ROCK		384	390	6
BLACK & RED ROCK		390	421	31
FRACTURED ROCK & CLAY		421	426	5
RED SANDY CLAY & ROCK		426	580	154
ROCK TRACE CLAY		580	605	25
CLAY & ROCK		605	700	95

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 620 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 700 Feet
18 Inches 0 Feet 620 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	22.36	.250	+ 2	260
10	22.36	.250	380	400
10	22.36	.250	500	520

Perforations:
 Type perforation LOUVERED-FUL FLOW
 Size perforation .125
 From 260 feet to 380 feet
 From 400 feet to 500 feet
 From 520 feet to 620 feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 100 feet to 620 feet

9. WATER LEVEL
 Static water level 195 feet below land surface
 Artesian flow 300 G.P.M. P.S.I.
 Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SARGENT IRRIGATION COMPANY
 Contractor
 Address 9955 N. VIRGINIA ST.
 Contractor
RENO, NV 89506

Nevada contractor's license number 21246
 issued by the State Contractor's Board

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller 1593 1493

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 2-12-96

NOVEMBER 03, 1995
 Date started
 Date completed 12-12 (Perforation w/ Driller) 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300	91	236