REVISED 02-12-96 Same Well as Log# 50265

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51443
Permit No. 4088
Basin

NOTICE OF INTENT NO. 21939

1. OWNER ST. JAMES VILLAGE
MAILING ADDRESS 11766 WILSHIRE BLVD.
SUITE 780 LOS ANGELES, CA. 90025

ADDRESS AT WELL LOCATION
ST. JAMES & JOY LAKE ROAD

2. LOCATION NW ¼ NW ¼ Sec. 14 T. 17 N/S R. 19 E. WASHOE County
PERMIT NO. 59631 (Issued by Water Resources) Parcel No. THE WOODA (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	10	10
SAND & CLAY COBBLES		10	50	40
SAND, SILT W/ CLAY		50	100	50
BLACK ROCK W/ CLAY		100	132	32
COARSE GRAVEL, CLAY		132	140	8
SANDY CLAY, GRAVEL		140	160	20
SAND & GRAVEL		160	172	12
ANDESITE - HARD		172	220	28
CLAY, BLACK ROCK		220	228	8
BROWN CLAY, ROCK		228	232	4
SAND, GRAVEL - FINE		232	260	28
ANDESITE		260	280	20
SAND GRAVEL COBBLES		280	312	32
BROKEN ROCK		312	317	5
SANDY W/ CHIPS		317	325	8
SANDY BROWN CLAY		325	330	5
BROWN CLAY, ROCK		330	340	10
BROKEN VOLCANICS		340	350	10
FINE BLACK CHIPS		350	380	30
BROKEN FRACTURED ROCK		380	400	20
BROKEN ANDESITE		400	415	15
RED ROCK		415	428	13
FRACTURED ROCK		428	435	7
BROKEN ROCK		435	438	3
BLACK CINDER ROCK		438	458	220
SANDY ROCK		458	498	40
ANDESITE		498	521	23
BROWN ANDESITE		521	535	14
BLACK ANDESITE		535	575	40
BROWN CLAY ROCK		575	605	30

Date started 11-28-95, 1920
Date completed 12-22-95, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
400	105	240

8. WELL CONSTRUCTION
Depth Drilled 596 Feet Depth Cased 590 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	605 Feet
18 Inches	0 Feet	595 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.250	[illegible]	350
10"		.25	490	510

Perforations:
Type perforation LOUVERED FUL-FLOW
Size perforation .125
From 350 feet to 490 feet
From 510 feet to 590 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 590 feet

9. WATER LEVEL
Static water level 242 feet below land surface
Artesian flow G.P.M. 400 P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. VIRGINIA ST. (Contractor)
RENO, NV. 89506

Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593

Signed [signature]
By driller performing actual drilling on site or contractor
Date DECEMBER 22, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627