

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 51445
 Permit No. _____
 Basin. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 90594

Consultant: WOODWARD-CLYDE Client: INTERSTATE BRANDS CORP.
 1. OWNER: WOODWARD-CLYDE ADDRESS AT WELL LOCATION: 1825 Glendale Ave. (formerly Continental Baking Company)
 MAILING ADDRESS: 10370 Old Placerville Rd, Ste 104 Sacramento, CA 95827 Sparks, NV

2. LOCATION: SW 1/4 NW 1/4 Sec 8 T 19N N/S R 20 E Washoe County
 PERMIT NO. R-283 VES-2 034-031-10 (@1817 Glendale Ave. (CBC) Sparks
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
3-13-96 VES-2 2 inch well				
Static water level @21.4 feet				
Total depth @27.4 feet				
Equipment used:				
Service truck, 2 man crew				
Walnut Grove High Pressure cement pump				
25 feet X 1" dia. tremie pipe				
Materials used:				
5 sacks of Portland Cement Type II				
1. Measure static water level				
2. Glue threaded adapter to existing casing				
3. Set tremie pipe to bottom of casing				
4. Pump neat cement from bottom to surface				
5. Pull tremie, fill casing & attach from cement pump directly to casing				
6. Pump cement @100 to @125 PSI squeezing cement through perforations into the surrounding formation. When pressure increases, disc.				
7. Remove traffic cover, cut casing below grade and patch with asphalt.				
Location:				
Very close to E of concrete slab S of building.				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)
 From To
Inches.....Feet.....Feet
Inches.....Feet.....Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured
 pumping.

Gravel Packed: Yes No
 From.....feet to.....feet

Date started..... 3-13-96 19
 Date completed..... 3-13-96 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level.....feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number 22549
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller.

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date March 18, 1996