WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51451
Permit No.
Basin 72B

NOTICE OF INTENT NO. 31464

1. OWNER Brady + Jan Bitz
MAILING ADDRESS 3181 Myles Dr Sparks N.V. 89439
ADDRESS AT WELL LOCATION 940 Orlando

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 21 N/S R. 19 E. Washoe County
PERMIT NO. 005585 (Issued by Water Resources) 08-413-13 (Parcel No.) Le Ray Valley Heper #4 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Loam		0	61	61
Light Sandy Clay		61	73	12
Brown Sandy Dirt		73	186	113
Light Brown Clay		186	210	24
Corse Gravel	20	210	230	20
Broken Granite		230	306	76
	11	290	301	11
39.692411°N GPS				
119.829924°W				
plugged by log # 112617				

Date started 1-26, 19 96
Date completed 2-5, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		

8. WELL CONSTRUCTION
Depth Drilled 306 Feet Depth Cased 306 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11	0	306

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	16	.188	+1	306

Perforations:
Type perforation Factory Slot
Size perforation ⅛x2"
From 210 feet to 230 feet
From 290 feet to 301 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 200 feet to 301 feet

9. WATER LEVEL
Static water level 162 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 49 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JM Drilling Co. (Contractor)
Address 1859 Hymer Ave (Contractor)
Sparks NV 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1940
Signed David E. [illegible] (By driller performing actual drilling on site or contractor)
Date 2-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627