WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51458
Permit No.
Basin 092A

NOTICE OF INTENT NO. 07971

1. OWNER DERMODY PROPERTIES
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1225 MOUNT BLVD STEAD NV.

2. LOCATION NE ¼ NW ¼ Sec. 31 T. 21 N/S R. 19 E/W Washoe County
PERMIT NO. Issued by Water Resources APN- ~~90-150038~~ 90-050-38 Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ PVC
☐ Air ☑ Other 1BA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Break end off of Btm of pvc. | | | | |
| Fill PVC w/ cement | | | | |
| pull pvc | | | | |
| Fill to GS w/cement | | | | |
| MW# SL 25 | | | | |

Date started 2-7, 1996
Date completed 2-7, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ? Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| ? Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | SCH 40 | | 0 | 5 |

Perforations:
Type perforation ~~SCOT~~ screen
Size perforation
From feet to feet
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 30
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc (Contractor)
Address 7 Slewers Peak Rd (Contractor) Carson City NV
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John G. Leisch (By driller performing actual drilling on site or contractor)
Date 2-25-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627