

OFFICE USE ONLY
 Log No. 51459
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31573

1. OWNER Mike Keife ADDRESS AT WELL LOCATION Lakeside Drive
 MAILING ADDRESS 1808 Frazer Avenue Parcel 2
Sparks, Nevada 89431 Reno Nevada 89511
 2. LOCATION ne 1/4 ne 1/4 Sec. 2 T. 18 N/S R. 19 East WASHOE County
 PERMIT NO. 041-110-71 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Multi colored gravels	0	35		
Brown Clay & multi colored gravels	35	45		
Brown Clay	45	95		
Multi colored gravel & brown clay	95	110		
Multi colored gravels	110	180		
Red gravel	180	238		
T.D. 238'				

8. WELL CONSTRUCTION
 Depth Drilled 238 Feet Depth Cased 238 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 238 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	-188	-1 1/2	238

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 238 feet to 218 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 238 feet to 100 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started May 11, 1996
 Date completed May 15, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18</u>		<u>2 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-a
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date May 28, 1996