WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51460
Permit No.
Basin 087

NOTICE OF INTENT NO. 30627

1. OWNER S & H INVESTMENTS/HUGH HUTCHINS
MAILING ADDRESS 1055 West Moana Ln. Suite #4
Reno, Nevada 89509

ADDRESS AT WELL LOCATION 460 Anitra Dr. Reno, Nevada 89511

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 18N N/S R. 19E E. Washoe County
PERMIT NO. R-282 (Issued by Water Resources) | 041-110-65 (Parcel No.) | Anitra Subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay some boulders		0	3	3
Brown clay		3	37	34
Volcanic rock		37	84	47
Soft reddish brown vol.rock		84	92	8
Brown volcanic rock		92	191	99
Brown sandy clay		191	212	21
Volcanic light brown		212	227	15
Light brown volcanic rock		227	333	106
Yellow volcanic rock		333	340	7
Fracture rock	X	340	366	26
Yellow volcanic rock		366	373	7
Fracture rock	X	373	441	68
Yellow volcanic rock		441	450	9

Date started 4-18-96, 19
Date completed 4-22-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+		

8. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	450 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	450

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From feet to feet
From 342 feet to 362 feet
From 382 feet to 442 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 450 feet

9. WATER LEVEL
Static water level 238 feet below land surface
Artesian flow G.P.M. 35+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING INC. (Contractor)
Address P.O BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 25, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627