WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51461
Permit No.
Basin 067

NOTICE OF INTENT NO. 33[illegible]9

1. OWNER BILL RENTSCH
MAILING ADDRESS 4045 Odile Crt.
Reno, Nevada 89511

ADDRESS AT WELL LOCATION 3900 Bowers Dr.
Reno, Nevada 89511

2. LOCATION SE ¼ SE ¼ Sec. 11 T. 18N N/S R. 19E E. Washoe County
PERMIT NO. (Issued by Water Resources) 040-491-22 (Parcel No.) South West Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil w/boulders		0	2	2
Boulder		2	5	3
Brown sandy clay, smaller boulder		5	36	31
Gravel and sand		36	41	5
Brown sand clay		41	56	15
Granite boulder		56	60	4
Brown sandy clay w/gravels smaller boulders		60	120	60
Gray volcanic rock		120	166	46
Fracture	X	166	170	4
Gray volcanic rock		170	189	19
Fracture	X	189	191	2
Gray volcanic rock		191	209	18
Reddish brown volcanic rock		209	211	2
Fracture	X	211	221	10
Reddish brown volcanic rock		221	225	4

Date started 5-13-96, 19
Date completed 5-14-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 227 Feet Depth Cased 227 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	227	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	227

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 180 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 227 feet

9. WATER LEVEL
Static water level 114 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (by driller performing actual drilling on site or contractor)
Date May 15, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627