WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51462
Permit No.
Basin 087

NOTICE OF INTENT NO. 29020

1. OWNER Larry Barnes
MAILING ADDRESS 15640 Fawn Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION SAME

2. LOCATION NW 1/4 SW 1/4 Sec. 36 T 18N N/S R 19E E Washoe County
PERMIT NO. 5645 (Issued by Water Resources) | 049-132-03 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tagged bottom at 190' and drilled				
to 290'. Tried to case from 185 to				
290' but casing hung up and				
wouldn't go to bottom even with				
repeated attempts.				
See next line	xx	190	222	100
Black & red Valcanics w/ quartz				
Black & Red shale	xx	222	242	20
Mostly white rock w/ quartz	x	242	290	48

Date started 5/9/96, 19__
Date completed 5/9/96, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	22	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 290 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/8" Inches		190 Feet	290 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	145	250

Perforations:
Type perforation Factory
Size perforation 3/32" x 3" SINGLE ROW
From 240 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 111 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality NOT TESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 5-13-96