

OFFICE USE ONLY  
 Log No. 51471  
 Permit No. 42403  
 Basin 084  
 26391

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26391

1. OWNER TRUCKEE MEADOWS FIRE PROTECTION DISTRICT  
 MAILING ADDRESS 1281 WOOD ROAD - VFD STATION 29  
RENO, NV 89510  
 ADDRESS AT WELL LOCATION 1400 WOOD ROAD, PALMINDO VALLEY STATION 29  
CC 15  
 2. LOCATION NE 1/4 SE 1/4 Sec. 6 T. 22N N/S R. 21 E WASHOE County  
 PERMIT NO. 5350  
 Issued by Water Resources Parcel No. 76-242-06 Subdivision Name PALMINDO VALLEY ESTATES  
2156214  
208 B

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & DR BROWN		0	80	80
GRAY VOLCANICS				
MED SOFT + SOFT.		80	210	130
GRAY VOLCANICS				
MED. SOFT - HARD	✓	210	360	150
GRANITIC FORMATION	✓	360	460	100
HARD TO MED HARD				
GRAY VOLCANICS	✓	460	500	40
ENCOUNTERED HOT WATER = 125°F				
GRAY VOLCANICS	✓	500	540	40
WATER COOLED				

8. WELL CONSTRUCTION  
 Depth Drilled 540 Feet Depth Cased 540 Feet  
 HOLE DIAMETER (BIT SIZE)  
 12" From 0 Feet 28" Feet  
 10" Inches 28 Feet 540 Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.75		.128	72'	540

Perforations:  
 Type perforation MECHANICAL  
 Size perforation 3/32" x 1 1/2"  
 From 150 feet to 540' feet  
 From \*feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55' feet to 540 feet

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Artesian flow No G.P.M. P.S.I.  
 Water temperature 60 °F Quality GOOD

Date started 4-14 1995  
 Date completed 4-27 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIRC</u>	<u>12</u>	<u>DUNK</u>	<u>5 HRS.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.M. BLAINE WELL DRILLER & PUMP CO.  
 Address 2545 WESTVIEW BLVD  
SPARKS, NV 89434  
 Nevada contractor's license number issued by the State Contractor's Board 10950  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4-26-95