WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 15BAA2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51473
Permit No.
Basin 084

NOTICE OF INTENT NO. 26388

1. OWNER GLORIA M. VILLATARO
MAILING ADDRESS 4955 AMY ROAD, SPARKS, NV 89436

ADDRESS AT WELL LOCATION 4955 AMY RD PALOMINO VALLEY, SPARKS, NV 89436

2. LOCATION NE ¼ NW ¼ Sec. 15 T 22N N/S R 21 E WASHOE County
PERMIT NO. 5337 (wa co) Issued by Water Resources | 77-130-08 Parcel No. | PALOMINO VALLEY ESTATES Unit 1 15.2.1.2 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY, SAND, COBBLES		0	20	20
BROKEN, WEATHERED VOLCANICS		20	200	180
SAND & FINE GRAVEL	✓	200	215	15
BROKEN, CEMENTED, WEATHERED VOLCANICS GRAY TO BROWN TO BLACK		215	340	125
Replacement of log 18576				

Date started 3-30, 1995
Date completed 4-12, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PAIL	18	—	5 HRS.

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	220 Feet
8 Inches	220 Feet	340 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2'	220
6 5/8		.188	210	340

Perforations:
Type perforation MECHANICAL SLOT
Size perforation 3/32" x 1 1/2
From 240 feet to 260 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W.M. BLAINE WELL DRLG & PUMP CO. Contractor
Address 2537 LARRY CIRCLE Contractor
CARSON CITY, NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 10950
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974
Signed [signature] $2410.00
By driller performing actual drilling on site or contractor
Date 4-12-95 $ 9900.00

ITS IF NECESSARY

(O)-627