WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51474
Permit No.
Basin 084

NOTICE OF INTENT NO. 36396

1. OWNER ANTHONY & INGRID SARANTITIS
MAILING ADDRESS 1179 PARK PACIFICA AVENUE PACIFICA, CA 94044
ADDRESS AT WELL LOCATION IRONWOOD ROAD PALOMINO VALLEY, SPARKS, NV. 89436

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 22 N/S R. 21 E. WASHOE County
PERMIT NO. 5305 (WaCo.) Issued by Water Resources | 76-220-0825 Parcel No. | PALOMINO VALLEY ESTATES. Unit 7 20-2-1-2 Subdivision Name Pas. 1

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DECOMPOSED GRANITE BUFF TO BROWN MED. SOFT TO FIRM.	*	0	360	360
GRANITE - LT. GRY TO GRY HARD WITH MED. HARD STRINGERS	**	360	640	280

*POSSIBLE WATER AT 340-360' - NO FORMATION CHANGES

** NO APPARANT FRACTURES HOWEVER WATER OUTPUT DID INCREASE

Date started 2-20, 1995
Date completed 3-2, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
PAIL	17	—	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 640' Feet Depth Cased 640' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	460 Feet
8 5/8" Inches	460 Feet	640 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2'	640

Perforations:
Type perforation MECHANICAL SLOT
Size perforation 3/32 x 2"
From 340' feet to 640 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 640 feet

9. WATER LEVEL
Static water level 240 feet below land surface
Artesian flow NONE G.P.M. — P.S.I.
Water temperature — °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P. WILLIAMS 702/358-8280 Contractor
Address 2545 WESTVIEW BLVD Contractor SPARKS, NV. 89434
Nevada contractor's license number issued by the State Contractor's Board 14483
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-5-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627